STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	315521	A. BUILDING **01** B. WING _____	**04/14/2023**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
SPRING HILLS POST ACUTE WOODBURY	**467 COOPER STREET** **WOODBURY, NJ 08096**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 000	Initial Comments This facility is in substantial compliance with Appendix Z - Emergency Preparedness for All Provider and Supplier Types Interpretive Guidance 483.73, Requirements for Long Term Care (LTC) Facilities.	E 000		
K 000	INITIAL COMMENTS A Life Safety Code Survey was conducted by the New Jersey Department of Health, Health Facility Survey and Field Operations on 04/13/2023 to 04/14/2023 and Atrium Post Acute Care of Woodbury was found to be in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR 483.90(a), Life Safety from Fire, and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19 EXISTING Health Care Occupancies. Atruim Post Acute Care of Woodbury is a one-story Type II Protected building that was built in 2016. The facility is divided into 10 smoke zones.	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

Electronically Signed | 05/16/2023

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients . (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.