

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315225	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 12/16/2022
NAME OF PROVIDER OR SUPPLIER RIVER FRONT REHABILITATION AND HEALTHCARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 5101 NORTH PARK DRIVE PENNSAUKEN, NJ 08109		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 000	Initial Comments An Emergency Preparedness Survey was conducted by Healthcare Management Solutions, LLC on behalf of the New Jersey Department of Health on 12/09/22. The facility was found to be in compliance with 42 CFR 483.73	E 000			
K 000	INITIAL COMMENTS A Life Safety Code Survey was conducted by the New Jersey Department of Health, Health Facility Survey and Field Operations on 12/09/22 was found to be in noncompliance with the requirements for participation in Medicare/Medicaid at 42 CFR 483.90(a), Life Safety from Fire, and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19 EXISTING Health Care Occupancy	K 000			
K 200 SS=F	Means of Egress Requirements - Other CFR(s): NFPA 101 Means of Egress Requirements - Other List in the REMARKS section any LSC Section 18.2 and 19.2 Means of Egress requirements that are not addressed by the provided K-tags, but are deficient. This information, along with the applicable Life Safety Code or NFPA standard citation, should be included on Form CMS-2567. 18.2, 19.2	K 200		1/30/23	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

12/30/2022

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315225	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 12/16/2022
NAME OF PROVIDER OR SUPPLIER RIVER FRONT REHABILITATION AND HEALTHCARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 5101 NORTH PARK DRIVE PENNSAUKEN, NJ 08109		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 200	<p>Continued From page 1</p> <p>This REQUIREMENT is not met as evidenced by: Based on observation and interview, the facility failed to ensure that the fire doors were inspected annually in accordance with NFPA 101 Life Safety Code (2012 edition) 7.2.1.15. This deficient practice had the potential to affect all 157 residents.</p> <p>Findings include:</p> <p>Observations of the facility's fire doors on 12/09/22 from 11:00 AM to 1:30 PM, revealed the door lacked the required inspection tags required to be placed on the doors after completed inspections. The Maintenance Director was present at the time of observation and confirmed the doors were not inspected. The Maintenance Director advised that he did not know that the fire doors had to be inspected annually by a qualified person who had knowledge of the fire doors and how they operate.</p> <p>Use NJAC 8:39-31.1(c), 31.2(e)</p>	K 200	<p>Immediate Corrective Action</p> <p>The facility fire door assemblies will be inspected by a qualified person by 1/30/23.</p> <p>Method to Assess Others</p> <p>All facility fire door assemblies were accounted for.</p> <p>No Residents were affected by this practice.</p> <p>All residents have the potential to be affected by this practice.</p> <p>Systematic Process</p> <p>Maintenance Department has been educated on fire safety and the need for all fire doors to be inspected.</p> <p>The Maintenance Department will continue to perform annual inspections of the facility fire door assemblies as part of the facility's life safety program.</p> <p>Quality Assurance</p> <p>Maintenance Director/Designee will do Quarterly audits x4 after that to ensure that door inspection is completed annually. Maintenance Director will</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315225	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 12/16/2022
NAME OF PROVIDER OR SUPPLIER RIVER FRONT REHABILITATION AND HEALTHCARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 5101 NORTH PARK DRIVE PENNSAUKEN, NJ 08109		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 200	Continued From page 2	K 200			
K 223 SS=E	<p>Doors with Self-Closing Devices CFR(s): NFPA 101</p> <p>Doors with Self-Closing Devices Doors in an exit passageway, stairway enclosure, or horizontal exit, smoke barrier, or hazardous area enclosure are self-closing and kept in the closed position, unless held open by a release device complying with 7.2.1.8.2 that automatically closes all such doors throughout the smoke compartment or entire facility upon activation of:</p> <ul style="list-style-type: none"> * Required manual fire alarm system; and * Local smoke detectors designed to detect smoke passing through the opening or a required smoke detection system; and * Automatic sprinkler system, if installed; and * Loss of power. <p>18.2.2.2.7, 18.2.2.2.8, 19.2.2.2.7, 19.2.2.2.8 This REQUIREMENT is not met as evidenced by:</p> <p>Based on observation and interview, the facility failed to maintain the means of egress for one of three stairway exit doors on the 2nd floor. The stairway exit door was missing a self-closing device in accordance with NFPA 101 Life Safety Code (2012 Edition) Sections 19.2.2.2.7. This deficient practice had the potential to affect 17 residents.</p> <p>Findings include:</p> <p>Observation on 12/09/22 at 1:06 PM, revealed that the stairway door was missing a self-closing device. At the time of the observation, the Maintenance Director verified the self-closing device was missing from the stairway door.</p>	K 223	<p>present audits to quarterly QAPI meeting x4 Quarters.</p> <p>Immediate Corrective Action</p> <p>The facility fire door assemblies will be inspected by a qualified person by 1/30/23.</p> <p>Method to Assess Others</p> <p>All facility fire door assemblies were accounted for.</p> <p>No Residents were affected by this practice.</p> <p>All residents have the potential to be affected by this practice.</p>	1/30/23	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315225	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 12/16/2022
NAME OF PROVIDER OR SUPPLIER RIVER FRONT REHABILITATION AND HEALTHCARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 5101 NORTH PARK DRIVE PENNSAUKEN, NJ 08109		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 223	Continued From page 3 NJAC 8:39-31.2(e)	K 223	<p>Systematic Process</p> <p>Maintenance Department has been educated on fire safety and the need for all fire doors to be inspected.</p> <p>The Maintenance Department will continue to perform annual inspections of the facility fire door assemblies as part of the facility's life safety program.</p> <p>Quality Assurance</p> <p>Maintenance Director/Designee will do Quarterly audits x4 after that to ensure that door inspection is completed annually. Maintenance Director will present audits to quarterly QAPI meeting x4 Quarters.</p>		
K 311 SS=E	<p>Vertical Openings - Enclosure CFR(s): NFPA 101</p> <p>Vertical Openings - Enclosure 2012 EXISTING Stairways, elevator shafts, light and ventilation shafts, chutes, and other vertical openings between floors are enclosed with construction having a fire resistance rating of at least 1 hour. An atrium may be used in accordance with 8.6. 19.3.1.1 through 19.3.1.6 If all vertical openings are properly enclosed with construction providing at least a 2-hour fire resistance rating, also check this box. This REQUIREMENT is not met as evidenced by: Based on observation and interview, the facility</p>	K 311	<p>Immediate Corrective Action</p>	1/30/23	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315225	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 12/16/2022
NAME OF PROVIDER OR SUPPLIER RIVER FRONT REHABILITATION AND HEALTHCARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 5101 NORTH PARK DRIVE PENNSAUKEN, NJ 08109		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 311	<p>Continued From page 4</p> <p>failed to maintain the means of egress for one of three stairway exit doors on the 2nd floor. The stairway exit door was missing a label that indicated the fire rating of the door in accordance with NFPA 101 Life Safety Code (2012 Edition) Sections 19.3.1.1. This deficient practice had the potential to affect 17 residents.</p> <p>Findings include:</p> <p>Observation on 12/09/22 at 1:06 PM, revealed the stairway exit door located on the 2nd floor, was missing the label indicating the fire rating of the door. At the time of the observation, the Maintenance Director verified the label was missing from the stairway door.</p> <p>NJAC 8:39-31.1 (c) NJAC 8:39-31.2 (e)</p>	K 311	<p>Stairway exit doors will be labeled with the fire rating attached to it.</p> <p>Method to Assess Others</p> <p>No Residents were affected by this practice.</p> <p>All residents have the potential to be affected by this practice.</p> <p>All other stairwell doors Have been inspected to ensure the presence of a fire rated label.</p> <p>Systematic Process</p> <p>Maintenance Department has been educated on fire safety and the need for all fire doors to be fire rated and labeled on the door.</p> <p>The Maintenance Director will continue to perform annual inspections of the facility stairwell doors to ensure the presence of a fire rated label as part of the facility's life safety program.</p> <p>Quality Assurance</p> <p>Maintenance Director will do monthly audits x4 after that to ensure all fire doors have been rated appropriately. Maintenance Director will present audits to quarterly QAPI meeting x2 Quarters</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315225	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 12/16/2022
NAME OF PROVIDER OR SUPPLIER RIVER FRONT REHABILITATION AND HEALTHCARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 5101 NORTH PARK DRIVE PENNSAUKEN, NJ 08109		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 345 K 345 SS=F	<p>Continued From page 5</p> <p>Fire Alarm System - Testing and Maintenance CFR(s): NFPA 101</p> <p>Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available. 9.6.1.3, 9.6.1.5, NFPA 70, NFPA 72 This REQUIREMENT is not met as evidenced by: Based on observation, interview, and document review, the facility failed to ensure smoke detection sensitivity testing was completed of the facility smoke detectors in accordance with NFPA 72 (2010 edition) section 14.4.5.3.2. This had the potential to affect all 157 residents.</p> <p>Findings include:</p> <p>Observation of the facility smoke detectors on 12/09/22 from 12:30 PM to 3:00 PM, revealed smoke detectors located in the corridors and other concealed areas throughout the building.</p> <p>Review of the facility fire alarm "Inspection and Testing Form" dated 07/26/22, provided by the Director of Maintenance, revealed no documented reference to a smoke detection sensitivity test.</p> <p>During an interview on 12/09/22 at 3:15 PM, the Director of Maintenance verified that the fire alarm sensitivity testing was not completed on the fire alarm system.</p>	K 345 K 345	<p>Immediate Corrective Action</p> <p>Sensitivity testing was performed by a 3rd party vendor.</p> <p>Method to Assess Others</p> <p>All facility smoke detectors were accounted for.</p> <p>No Residents were affected by this practice.</p> <p>All residents have the potential to be affected by this practice.</p> <p>Systematic Process</p> <p>Maintenance Department has been educated on fire safety and the need for sensitivity testing for all smoke detectors throughout the building.</p> <p>The Maintenance Director will continue to</p>	1/30/23	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/30/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315225	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 12/16/2022
NAME OF PROVIDER OR SUPPLIER RIVER FRONT REHABILITATION AND HEALTHCARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 5101 NORTH PARK DRIVE PENNSAUKEN, NJ 08109		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 345	Continued From page 6 NJAC 8:39-31.2(e)	K 345	<p>coordinate on an ongoing basis with a third-party fire alarm system vendor to perform biennial smoke detector sensitivity testing as part of the facility's life safety program.</p> <p>Quality Assurance</p> <p>Maintenance Director/Designee will do bi-annual audits x4 after that to ensure sensitivity testing is completed Biennially. Maintenance Director will present audits to quarterly QAPI meeting x4 Quarters.</p>		

POST-CERTIFICATION REVISIT REPORT

PROVIDER / SUPPLIER / CLIA / IDENTIFICATION NUMBER 315225	MULTIPLE CONSTRUCTION A. Building 01 - COOPER RIVER WEST B. Wing	DATE OF REVISIT 2/9/2023
NAME OF FACILITY RIVER FRONT REHABILITATION AND HEALTHCARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 5101 NORTH PARK DRIVE PENNSAUKEN, NJ 08109	

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction, that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

ITEM Y4	DATE Y5	ITEM Y4	DATE Y5	ITEM Y4	DATE Y5
ID Prefix	Correction	ID Prefix	Correction	ID Prefix	Correction
Reg. #	Completed	Reg. #	Completed	Reg. #	Completed
LSC	01/30/2023	LSC	01/30/2023	LSC	01/30/2023
ID Prefix	Correction	ID Prefix	Correction	ID Prefix	Correction
Reg. #	Completed	Reg. #	Completed	Reg. #	Completed
LSC	01/30/2023	LSC		LSC	
ID Prefix	Correction	ID Prefix	Correction	ID Prefix	Correction
Reg. #	Completed	Reg. #	Completed	Reg. #	Completed
LSC		LSC		LSC	
ID Prefix	Correction	ID Prefix	Correction	ID Prefix	Correction
Reg. #	Completed	Reg. #	Completed	Reg. #	Completed
LSC		LSC		LSC	
ID Prefix	Correction	ID Prefix	Correction	ID Prefix	Correction
Reg. #	Completed	Reg. #	Completed	Reg. #	Completed
LSC		LSC		LSC	
REVIEWED BY STATE AGENCY	REVIEWED BY (INITIALS)	DATE	SIGNATURE OF SURVEYOR	DATE	
REVIEWED BY CMS RO	REVIEWED BY (INITIALS)	DATE	TITLE	DATE	
FOLLOWUP TO SURVEY COMPLETED ON 12/16/2022		<input type="checkbox"/> CHECK FOR ANY UNCORRECTED DEFICIENCIES. WAS A SUMMARY OF UNCORRECTED DEFICIENCIES (CMS-2567) SENT TO THE FACILITY? <input type="checkbox"/> YES <input type="checkbox"/> NO			