

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/12/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315387	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 06/28/2022
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ALLAIRE REHAB & NURSING	STREET ADDRESS, CITY, STATE, ZIP CODE 115 DUTCH LANE ROAD FREEHOLD, NJ 07728
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

F 000	<p>INITIAL COMMENTS</p> <p>TYPE OF SURVEY: New Construction and Renovation Project: Phase 2 of their Renovation/Construction project consisting of four renovated resident rooms: 240, 241, 242, and 243.</p> <p>SURVEY DATE: 6/28/22</p> <p>The facility is in substantial compliance with the requirements of 42 CFR Part 483, Subpart B, for Long Term Care Facilities.</p> <p>The above noted areas may not be occupied until formal notification by the Certificate of Need and Licensing Division has been received.</p>	F 000		
-------	--	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 07/12/2022
--	-------	-----------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/12/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315387	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 06/28/2022
NAME OF PROVIDER OR SUPPLIER ALLAIRE REHAB & NURSING			STREET ADDRESS, CITY, STATE, ZIP CODE 115 DUTCH LANE ROAD FREEHOLD, NJ 07728	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS TYPE OF SURVEY: New Construction and Renovation Project: Phase 2 of their Renovation/Construction project consisting of four renovated resident rooms: 240, 241, 242, and 243. A Life Safety Code Survey was conducted by the New Jersey Department of Health, Health Facility Survey and Field Operations on 6/28/22 and Allaire Rehab & Nursing was found to be in noncompliance with the requirements for participation in Medicare/Medicaid at 42 CFR 483.90(a), Life Safety from Fire, and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19 EXISTING Health Care Occupancies. Building: Construction Classification Type 11-A (fire Resistive) NFPA 220 Building Construction Type 11 (111) Stories-3 plus ground floor (Existing) The above noted areas may not be occupied until formal notification by the Certificate of Need and Licensing Division has been received.	K 000		
K 345 SS=F	Fire Alarm System - Testing and Maintenance CFR(s): NFPA 101 Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available.	K 345		6/30/22

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

07/12/2022

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315387	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 06/28/2022
NAME OF PROVIDER OR SUPPLIER ALLAIRE REHAB & NURSING			STREET ADDRESS, CITY, STATE, ZIP CODE 115 DUTCH LANE ROAD FREEHOLD, NJ 07728	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 345	<p>Continued From page 1</p> <p>9.6.1.3, 9.6.1.5, NFPA 70, NFPA 72</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Based on observation and interview on 6/28/22, it was determined that the facility failed to ensure that their building's fire alarm system was maintained in accordance with the requirements of NFPA 70 and 72.</p> <p>This deficient practice had the potential to affect all residents in the facility and was evidenced by the findings noted below:</p> <p>On 6/28/22 at approximately 9:00 AM, in the presence of the facility's Administrator and the Regional Plant Operations Director, the surveyor observed that the fire alarm annunciator panel indicated, "Trouble in System." The surveyor observed that the amber trouble light was activated in 2 of 2 panels (the main entrance panel and floor 2 panel outside the nurses station).</p> <p>The annunciator panel indicated: Acknowledged Trouble- Battery Trouble</p> <p>The prior facility's name was indicated on the panel as [prior facility name redacted] and indicated: "time 01:22:42A Monday May 30, 2022 TROUBLE: 003. "</p> <p>The facility provided a document from the facility's fire alarm vendor: which included, " We are aware of the trouble on the fire alarm system. The trouble will require the installer of the panel to be present for repair. We are working to resolve this as soon as possible. The system is currently functioning as it should." This document was signed and dated with today's date of June 28,</p>	K 345	<p>1) On 6/30/2022 our vendor came to the facility to remove the "trouble in system" alert. It was cleared on both annunciator panels, the main entrance and the 2nd floor.</p> <p>2) All residents have the potential to be affected by this deficient practice.</p> <p>3) The maintenance director and administrator were in-serviced on the regulation of keeping a fire alarm system in compliance with the requirements of recording system acceptance, maintenance, and testing to be readily available.</p> <p>4) The maintenance director or designee will check the fire annunciator panel weekly at both locations to ensure that system is "not in trouble." Audits will take place weekly x 2 beginning 6/28/22 and monthly x 3 months. Results of the audit will be reviewed at the quarterly QAPI meeting.</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/12/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 315387	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 06/28/2022
NAME OF PROVIDER OR SUPPLIER ALLAIRE REHAB & NURSING			STREET ADDRESS, CITY, STATE, ZIP CODE 115 DUTCH LANE ROAD FREEHOLD, NJ 07728		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 345	Continued From page 2 2022. 9.6.1.5* To ensure operational integrity, the fire alarm system shall have an approved maintenance and testing program complying with the applicable requirements of NFPA 70, National Electrical Code, and NFPA 72, National Fire Alarm and Signaling Code. The Administrator and Regional Plant Operations Director stated that the facility fire alarm vendor was scheduled to respond as soon as possible (ASAP). The Administrator was informed of the surveyor's findings at the Life Safety Code exit conference on 6/28/22. NFPA 70 NFPA 72 NJAC 8:39-31.2(e)	K 345			

POST-CERTIFICATION REVISIT REPORT

PROVIDER / SUPPLIER / CLIA / IDENTIFICATION NUMBER 315387	Y1	MULTIPLE CONSTRUCTION A. Building 01 - MAIN BUILDING 01 B. Wing	Y2	DATE OF REVISIT 7/15/2022	Y3
NAME OF FACILITY ALLAIRE REHAB & NURSING			STREET ADDRESS, CITY, STATE, ZIP CODE 115 DUTCH LANE ROAD FREEHOLD, NJ 07728		

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction, that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

ITEM Y4	DATE Y5	ITEM Y4	DATE Y5	ITEM Y4	DATE Y5
ID Prefix _____ Reg. # NFPA 101 LSC K0345	Correction Completed 06/30/2022	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed

REVIEWED BY STATE AGENCY <input type="checkbox"/>	REVIEWED BY (INITIALS)	DATE	SIGNATURE OF SURVEYOR	DATE
REVIEWED BY CMS RO <input type="checkbox"/>	REVIEWED BY (INITIALS)	DATE	TITLE	DATE

FOLLOWUP TO SURVEY COMPLETED ON 6/28/2022	<input type="checkbox"/> CHECK FOR ANY UNCORRECTED DEFICIENCIES. WAS A SUMMARY OF UNCORRECTED DEFICIENCIES (CMS-2567) SENT TO THE FACILITY?	<input type="checkbox"/> YES <input type="checkbox"/> NO
--	---	--